10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTER : DELHI FIRE SERVICE NEW DELHI

No F.DD:CMS/2009/ 1974 Dated 2/11/09

To

Sh. Vijay Sharma (Manager)
Sant Nirankari Boys Sr. Sec. School
Sant Nirankari Colony, Delhi-9

Sub: Regarding Issue of NOC (Objection Certificate) in R/o Sant Nirankari Colony, Delhi-9

Sir,

Please refer to your letter No SNBSS/2009-10 dated 14/9/09 on the subject cited above. In this regard it is to inform you that the inspection/ re-inspection of the above said school has been carried out by the officer concerned of this department from fire safety point of view on 31/10/09

During the course of inspection, it was observed that The school is located on the 1st and 2nd floor and approachable to Fire Engine. The bldg. is comprised of Ground + 1st floor having 3 nos. Staircases. There are 36 nos. of Classrooms i.e. 18 rooms on 1st floor, 12 nos. Staff rooms, 1 Computer room, 2 nos. Principal rooms, 1 Science Lab, 1 Computer room and 2 nos. Electrical/Engg. Services Lab/Workshop, MCR i.e. as provided, No Emergency Phone is provided. Fire fighting arrangements such as 6 nos. Fire Extinguishers (Water CO2, Type), Down Comer Hydrant system, Type of fire, fire detection, fire alarm system, Public address system, Emergency lights are provided in good working order. The Capacity of the school is 4316 m² Nos. of students is 1800

Keeping in view of the above, this department has No Objection from fire safety point of view as the school authorities have been provided the fire safety arrangements as per the circular of Director of Education Vide letter No. 262-362 dated 17.01.2005. However, the following fire safety directives must be adhered to

1. Means of escape shall always be kept free every obstruction and same shall not be locked or bolted from outside and are easily openable by occupants in any emergency.
2. All the existing fire safety arrangements / equipments shall be maintained properly as found during inspection.
3. All employees / occupants / students shall be acquainted with the use and maintenance of the fire fighting equipments / installation.
4. All furniture of the school including chair and tables shall be coated with the fire retardant paint within three years.
5. Basement shall be used as per Building Bye Laws.

Yours faithfully

Chief Fire Officer
Delhi Fire Service

Copy to
1. The Addl. Director (Admn.)
Directorate of Education
Govt. of NCT of Delhi, Delhi.

Principal
Sant Nirankari Boys Sr. Sec. School
Sant Nirankari Colony, Delhi-9

Chairman
Sant Nirankari Boys Sr. Sec. School
Sant Nirankari Colony, Delhi-9